

Facility Summary in BIG HORN County in the City of CROW AGENCY

Location: TEEPEE SERVICE INC
 EXIT 509 INTERSTATE 90 PO BOX 280
 CROW AGENCY, MT 59022 BIG HORN
Contact: Edward Watt, (406) 638-7277

Sys Fac ID: 02-07334
Last Inspected On: 1/27/2016
Operating Permit Renewal Date: 7/7/2019

Owners/Operators: Teepee Service Inc, Owner (406)-638-2269 PO BOX 245
 CROW AGENCY MT 59022-0245
 James Watt, UST Class A Operator
 James Watt, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
7	20	7/3/1995	Steel Clad	Flexible Plastic	High Level Alarm
2097			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		4/16/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	20	7/3/1995	Steel Clad	Flexible Plastic	High Level Alarm
2098			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		4/16/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in BIG HORN County in the City of CROW AGENCY

Location: LITTLE BIG HORN CAMP
 INTERSTATE 90 & US HIGHWAY 212
 CROW AGENCY, MT 59022 BIG HORN
Contact: Paul Pryor, (406) 861-4859

Sys Fac ID: 02-08937
Last Inspected On: 9/11/2013
Operating Permit Renewal Date:

Owners/Operators: Sumack Trust, Owner (406)-638-2232 DBA LITTLE BIGHORN CAMP
 PO BOX 266
 CROW AGENCY MT 59022-0266

R F Mische, UST Class A Operator
 R F Mische, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	17	1/1/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3919			Double-Walled	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		9/13/2010	Continuous Interstitial Monitor	Not Listed	
8,000					
4	17	1/1/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3920			Double-Walled	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		9/13/2010	Continuous Interstitial Monitor	Not Listed	
12,000					

Facility Summary in BIG HORN County in the City of CROW AGENCY

Location: Crow Nation Express
 US HIGHWAY 212 & INTERSTATE 90
 CROW AGENCY, MT 59022 BIG HORN
Contact: Robin Vallie, (406) 245-6376

Sys Fac ID: 02-10867
Last Inspected On: 12/16/2014
Operating Permit Renewal Date: 1/6/2018

Owners/Operators: Crow Tribe of Indians, Owner (406)-638-2400 PO BOX 179
 CROW AGENCY MT 59022

Mykel Stockton, UST Class A Operator
 Robin Vallie, UST Class A Operator
 Robin Vallie, UST Class B Operator
 Christopher Stockton, UST Class B Global Operator
 Joseph Stockton, UST Class B Global Operator
 Mykel Stockton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	16	2/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4174			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		12/21/2011	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
10,000		8/2/2015	TLS-350/Gilbarco EMC , Veeder Root		
6	16	2/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4175			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		12/21/2011	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
6,000		8/2/2015	TLS-350/Gilbarco EMC , Veeder Root		
7	16	2/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4176			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		12/21/2011	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
4,000		8/2/2015	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in BIG HORN County in the City of CROW AGENCY

Location: Crow Nation Express
 US HIGHWAY 212 & INTERSTATE 90
 CROW AGENCY, MT 59022 BIG HORN

Contact: Robin Vallie, (406) 245-6376

Sys Fac ID: 02-10867
Last Inspected On: 12/16/2014
Operating Permit Renewal Date: 1/6/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
8	16	2/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4177			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/21/2011	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
6,000		8/2/2015	TLS-350/Gilbarco EMC , Veeder Root		
9	16	2/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4178			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/21/2011	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
4,000		8/2/2015	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in BIG HORN County in the City of FORT SMITH

Location: YELLOWTAIL MARKET
 PARKDALE COURT
 FORT SMITH, MT 59035 BIG HORN

Sys Fac ID: 02-05862

Last Inspected On: 5/19/2015

Operating Permit Renewal Date: 10/20/2018

Contact: Kerry Stewart, (406) 666-2333

Owners/Operators: Crow Tribe of Indians, Owner (406)-638-2059 PO BOX 159
 CROW AGENCY MT 59022
 Apsaalooke Nights Casino, Operator (406)-638-4440 PO BOX 609
 CROW AGENCY MT 59022
 Brenda Fenner, UST Class A Operator
 Kerry Stewart, UST Class A Operator
 Brenda Fenner, UST Class B Operator
 Kerry Stewart, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	17	3/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1210			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		5/19/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		1/18/2015	TLS-350/Gilbarco EMC , Veeder Root		
4	17	3/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1211			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/19/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		1/20/2015	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in BIG HORN County in the City of FORT SMITH

Location: BIGHORN CANYON MAINTENANCE FACILITY
5TH AVE B
FORT SMITH, MT 59035 BIG HORN

Sys Fac ID: 02-09815

Last Inspected On: 11/30/2015

Operating Permit Renewal Date: 4/26/2019

Contact: Joe Bartlette, (406) 666-2412

Owners/Operators: National Park Service Yellowtail, Owner (406)-666-3311 PO BOX 7458
YELLOWTAIL MT 59035-7458

Lyndon Driftwood, UST Class A Operator
Lyndon Driftwood, UST Class B Global Operator
Roger Watson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	28	1/1/1988	Cathodically Protected Steel	Flexible Plastic	High Level Alarm, Ball Float Valve
1746		12/18/2012	Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		11/5/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
2,000		11/5/2015	TLS-300 , Veeder Root	Continuous Interstitial Monitor	
3	28	1/1/1988	Cathodically Protected Steel	Flexible Plastic	High Level Alarm, Ball Float Valve
1745		12/18/2012	Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		11/5/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
2,000		11/5/2015	TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in BIG HORN County in the City of FORT SMITH

Location: OK A BEH MARINA
5TH AVE B
FORT SMITH, MT 59035 BIG HORN

Sys Fac ID: 56-13877

Last Inspected On: 5/11/2015

Operating Permit Renewal Date: 5/11/2018

Contact: Ernest Redden, (406) 666-3311

Owners/Operators: National Park Service Yellowtail, Owner (406)-666-3311 PO BOX 7458
YELLOWTAIL MT 59035-7458
Lyndon Driftwood, UST Class A Operator
Roger Watson, UST Class A Operator
Lyndon Driftwood, UST Class B Global Operator
Roger Watson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	25	5/14/1990	Cathodically Protected Steel	Flexible Plastic	Positive Shutoff
1747		6/18/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Gasoline		12/3/2012	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
2,000		6/18/2013	TLS-300 , Veeder Root		

Facility Summary in BIG HORN County in the City of GARRYOWEN

Location: GARRYOWEN CONOCO
GARRYOWEN FRONTAGE RD
GARRYOWEN, MT 59031 BIG HORN

Contact: Chris Kortlander, (406) 638-2020

Sys Fac ID: 02-03284
Last Inspected On: 7/14/2014
Operating Permit Renewal Date: 8/13/2017

Owners/Operators: Neda LLC, Owner (406)-638-2020 ATTN CHRIS KORTLANDER
PO BOX 200
GARRYOWEN MT 59031-0200

Chris Kortlander, Operator (406)-638-2020 PO BOX 200
GARRYOWEN MT 59031-0200

Chris Kortlander, UST Class A Operator
Petra Pretty On Top, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	19	6/21/1996	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
3392			Double-Walled	Secondary Containment Chase	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/29/2008	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
8,000		6/18/2013	TLS-300 , Veeder Root	Continuous Interstitial Monitor	
2	19	6/21/1996	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
3393			Double-Walled	Secondary Containment Chase	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/29/2008	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
12,000		6/18/2013	TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in BIG HORN County in the City of HARDIN

Location: DOLLIES CONVENIENCE STORE
804 W 3RD ST
HARDIN, MT 59034 BIG HORN
Contact: Chetan Pater, (605) 517-1140

Sys Fac ID: 02-00061
Last Inspected On: 1/21/2015
Operating Permit Renewal Date: 3/14/2018

Owners/Operators: Jagadish LLC, Owner (605)-517-1140 804 W 3RD ST
HARDIN MT 59034
Pooja LLC DBA Dollies, Operator (605)-517-1140 804 W 3RD ST
HARDIN MT 59034
Megan Ashinhurst, UST Class A Operator
Victor F Uffelman, UST Class A Operator
Angelica Wiley, UST Class A Operator
Corri Duncan, UST Class B Operator
Constance Weigand, UST Class B Operator
Megan Ashinhurst, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	31	12/20/1984	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4463			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		1/16/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		1/21/2015	TLS-300 , Veeder Root		
3	13	12/16/2002	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4773			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		1/16/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		1/21/2015	TLS-300 , Veeder Root		

Facility Summary in BIG HORN County in the City of HARDIN

Location: GOOD 2 GO STORE LLC
1600 CRAWFORD AVE
HARDIN, MT 59034 BIG HORN

Contact: Brad Hinze, (406) 665-2920

Sys Fac ID: 02-00538
Last Inspected On: 8/22/2013
Operating Permit Renewal Date: 12/11/2016

Owners/Operators: #8 Hardin Montana Property LLC, Owner (208)-523-6582 PO BOX 50620
IDAHO FALLS ID 83405
Good 2 Go Stores LLC, Operator (307)-899-1051 1600 NORTH CRAWFORD
HARDIN MT 59034
Paul Ferro, UST Class A Operator
Brad Hinze, UST Class A Operator
Kenneth Knight, UST Class A Operator
Paul Ferro, UST Class B Operator
Brad Hinze, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	41	4/12/1974	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3790			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		8/8/2007	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
6,000		7/31/2010			
3	41	4/12/1974	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3789			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		8/28/2007	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
6,000		7/31/2010			
5	41	4/12/1974	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3791			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		8/28/2007	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
6,000		7/31/2010			

Facility Summary in BIG HORN County in the City of HARDIN

Location: GOOD 2 GO STORE LLC
 1600 CRAWFORD AVE
 HARDIN, MT 59034 BIG HORN
Contact: Brad Hinze, (406) 665-2920

Sys Fac ID: 02-00538
Last Inspected On: 8/22/2013
Operating Permit Renewal Date: 12/11/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
6	41	4/12/1974	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3792			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		9/7/2007	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
6,000		7/31/2010			

Facility Summary in BIG HORN County in the City of HARDIN

Location: TOWN AND COUNTRY SUPPLY #48
225 W RAILROAD ST PO BOX 385
HARDIN, MT 59034 BIG HORN

Sys Fac ID: 02-01403

Last Inspected On: 11/5/2013

Operating Permit Renewal Date: 12/10/2016

Contact: Ronald Nedens, (406) 665-1103

Owners/Operators: Town & Country Supply Association, Owner/Operator (406)-628-6314 PO BOX 367
LAUREL MT 59044-0367

Steven Shelton, UST Class A Operator
Leonard Zier, UST Class A Operator
Connie Roundtree, UST Class B Global Operator
Steven Shelton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	25	6/1/1990	Bare Steel	Fiberglass Reinforced Plastic	
923	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
6,000		5/29/2013			
3	25	6/1/1990	Bare Steel	Fiberglass Reinforced Plastic	
924	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
6,000		5/29/2013			
4	25	6/1/1990	Bare Steel	Fiberglass Reinforced Plastic	
925	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
6,000		5/29/2013			
5	25	6/1/1990	Bare Steel	Fiberglass Reinforced Plastic	
926	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	MLLD Line Tightness Testing	
6,000		5/29/2013			

Facility Summary in BIG HORN County in the City of HARDIN

Location: WAGNER TRAVEL SHOPPE EXPRESS STOP
1424 N CRAWFORD AVE
HARDIN, MT 59034 BIG HORN

Sys Fac ID: 02-04841

Last Inspected On: 11/19/2014

Operating Permit Renewal Date: 1/6/2018

Contact: Larry Wagner, (406) 665-1061

Owners/Operators: Stockton Oil Company, Owner (406)-245-6376 PO BOX 1756
BILLINGS MT 59103-1756

Mykel Stockton, UST Class A Operator
Sue Nutgens, UST Class B Operator
Christopher Stockton, UST Class B Global Operator
Joseph Stockton, UST Class B Global Operator
Mykel Stockton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	26	1/1/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, Auto Shutoff
2231			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation	MLLD Line Tightness Testing	
10,000		5/26/2011			
5	26	1/1/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, Auto Shutoff
2232			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation	MLLD Line Tightness Testing	
10,000		5/26/2011			
6	26	1/1/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, Auto Shutoff
2233			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation	MLLD Line Tightness Testing	
6,000		5/26/2011			

Facility Summary in BIG HORN County in the City of HARDIN

Location: WAGNER TRAVEL SHOPPE EXPRESS STOP
1424 N CRAWFORD AVE
HARDIN, MT 59034 BIG HORN

Sys Fac ID: 02-04841

Last Inspected On: 11/19/2014

Operating Permit Renewal Date: 1/6/2018

Contact: Larry Wagner, (406) 665-1061

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
7	36	4/3/1979	Bare Steel	Fiberglass Reinforced Plastic	
2234	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
14,000		5/26/2011			
8	36	4/3/1979	Bare Steel	Fiberglass Reinforced Plastic	
2235	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
14,000		5/26/2011			
9	36	4/3/1979	Bare Steel	Fiberglass Reinforced Plastic	
2236	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
14,000		5/26/2011			

Facility Summary in BIG HORN County in the City of HARDIN

Location: FOX SERVICE CENTER UST
25 3RD ST E
HARDIN, MT 59034 BIG HORN

Sys Fac ID: 02-05561

Last Inspected On: 2/23/1999

Operating Permit Renewal Date:

Contact: Dennis Fox, (406) 665-3648

Owners/Operators: Hanser Holding LLC, Owner

(406)-248-7795

430 S BILLINGS BLVD
BILLINGS MT 59101-4703

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
10	51	1/1/1965	Bare Steel	Other	
0			None	None	No
Currently in Use			Not Required	Not Listed	Galvanic
Hydraulic Fluid			Inventory Reconciliation, Not Listed	Not Listed	
40					
11	51	1/1/1965	Bare Steel	Other	
0			None	None	No
Currently in Use			Not Required	Not Listed	Galvanic
Hydraulic Fluid			Inventory Reconciliation, Not Listed	Not Listed	
40					

Facility Summary in BIG HORN County in the City of HARDIN

Location: BAIRS TRUCK STOP HARDIN
315 13TH ST W
HARDIN, MT 59034 BIG HORN
Contact: Rick Freeman, (406) 665-1237

Sys Fac ID: 02-05752
Last Inspected On: 4/16/2013
Operating Permit Renewal Date: 6/1/2016

Owners/Operators: Alsaker Corp, Owner (509)-534-1502 DBA BROADWAY TRUCK STOPS
PO BOX 14646
SPOKANE VALLEY WA 99214-0646

Rocco Cooper, UST Class A Operator
Paul Dallas, UST Class A Operator
Arthur Jemerigbe, UST Class A Operator
Paul Dallas, UST Class B Operator
Arthur Jemerigbe, UST Class B Operator
Lynn Peterson, UST Class B Operator
Rocco Cooper, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	46	4/25/1969	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3894			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		4/6/2013	Stat. Inventory Reconciliation	MLLD Line Tightness Testing	
10,000		2/7/2013			
3	36	4/26/1979	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3895			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		4/16/2013	Stat. Inventory Reconciliation	MLLD Line Tightness Testing	
10,000		1/4/2013			
4	46	4/25/1969	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3896			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		4/16/2013	Stat. Inventory Reconciliation	MLLD Line Tightness Testing	
6,000		1/4/2013			

Facility Summary in BIG HORN County in the City of HARDIN

Location: L & B LAST STOP
 531 E RAILWAY ST
 HARDIN, MT 59034 BIG HORN
Contact: Lynette & Gary Vandersloot, (406) 665-3414

Sys Fac ID: 02-05856
Last Inspected On: 5/29/2013
Operating Permit Renewal Date: 7/16/2016

Owners/Operators: Gary VanDersloot, Owner (406)-665-3414 PO BOX 156
 HARDIN MT 59034-0156
 Lynette VanDersloot, Owner (406)-665-3414 PO BOX 156
 HARDIN MT 59034-0156
 Lynette Vandersloot, UST Class A Operator
 Lynette Vandersloot, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	17	1/1/1999	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
3915			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		5/29/2013	Continuous Interstitial Monitor	Not Listed	
4,000					
4	17	1/1/1999	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
3916			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		5/29/2013	Continuous Interstitial Monitor	Not Listed	
2,000					

Facility Summary in BIG HORN County in the City of HARDIN

Location: TOWN PUMP INC HARDIN
1010 N CRAWFORD AVE
HARDIN, MT 59034 BIG HORN

Sys Fac ID: 02-08703

Last Inspected On: 3/7/2013

Operating Permit Renewal Date: 4/27/2016

Contact: Trent Biggers, (406) 497-6700

Owners/Operators: Town Pump of Hardin Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000
Trent Biggers, UST Class A Operator
Daniel Sampson, UST Class A Operator
Trent Biggers, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	31	10/1/1984	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2377			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/4/2013	Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000					
2	31	10/1/1984	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2378			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/4/2013	Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000					
3	31	10/1/1984	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2379			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		3/4/2013	Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000					

Facility Summary in BIG HORN County in the City of HARDIN

Location: TOWN PUMP INC HARDIN
1010 N CRAWFORD AVE
HARDIN, MT 59034 BIG HORN

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 02-08703
Last Inspected On: 3/7/2013
Operating Permit Renewal Date: 4/27/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	34	4/14/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2380			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		3/4/2013	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000					
5	39	1/1/1977	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
2381			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/4/2013	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
6,000					
6	15	5/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4362			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/14/2009	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000					
7	15	5/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4363			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/14/2009	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
5,000					

Facility Summary in BIG HORN County in the City of HARDIN

Location: TOWN PUMP INC HARDIN
1010 N CRAWFORD AVE
HARDIN, MT 59034 BIG HORN

Sys Fac ID: 02-08703

Last Inspected On: 3/7/2013

Operating Permit Renewal Date: 4/27/2016

Contact: Trent Biggers, (406) 497-6700

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
8	15	5/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4364			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/14/2009	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000					

Facility Summary in BIG HORN County in the City of HARDIN

Location: BIG HORN COUNTY COMMUNITY SERVICE FACILITY
809 N CUSTER AVE
HARDIN, MT 59034 BIG HORN

Sys Fac ID: 02-10287

Last Inspected On: 11/4/2014

Operating Permit Renewal Date: 1/17/2018

Contact: Craig Taft, (406) 665-1005

Owners/Operators: Big Horn County Health Dept, Owner (406)-665-8720 809 N CUSTER AVE
HARDIN MT 59034-1311
Craig Taft, UST Class A Operator
Craig Taft, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	17	11/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
443			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		12/21/2011	Continuous Interstitial Monitor	Continuous Interstitial Monitor, Deferred	
2,000					

Facility Summary in BIG HORN County in the City of HARDIN

Location: MATOVICH OIL CO INC
900 4TH ST W
HARDIN, MT 59034 BIG HORN
Contact: Jon Matovich, (406) 665-1400

Sys Fac ID: 02-13423
Last Inspected On: 11/4/2014
Operating Permit Renewal Date: 3/5/2018

Owners/Operators: Matovich Oil Co Inc, Owner (406)-665-1400 PO BOX 431
HARDIN MT 59034-0431
John Darr Matovich, UST Class A Operator
John Darr Matovich, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	21	5/24/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1582			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/4/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
4,000		9/10/2014			
2	21	5/24/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1583			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/4/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
4,000		9/10/2014			
3	21	5/24/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1580			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/4/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
2,000		9/10/2014			
4	21	5/24/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1581			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/4/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
2,000		9/10/2014			

Facility Summary in BIG HORN County in the City of HARDIN

Location: HARDIN C STORE
1223 N CRAWFORD AVE
HARDIN, MT 59034 BIG HORN

Sys Fac ID: 02-13635

Last Inspected On: 9/23/2013

Operating Permit Renewal Date: 12/10/2016

Contact: Ronald Nedens, (406) 665-1155

Owners/Operators: Town & Country Supply Association, Owner/Operator (406)-628-6314 PO BOX 367
LAUREL MT 59044-0367

Steven Shelton, UST Class A Operator
Peggy DelCamp, UST Class B Operator
Ronnie Lane, UST Class B Operator
Steven Shelton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	20	7/1/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
927			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/23/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
16,000		9/2/2010			
2	20	7/1/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
928			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/23/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
16,000		9/2/2010			
3	20	7/1/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
929			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/23/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
16,000		9/2/2010			

Facility Summary in BIG HORN County in the City of HARDIN

Location: HARDIN C STORE
1223 N CRAWFORD AVE
HARDIN, MT 59034 BIG HORN

Contact: Ronald Nedens, (406) 665-1155

Sys Fac ID: 02-13635
Last Inspected On: 9/23/2013
Operating Permit Renewal Date: 12/10/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	20	7/1/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
930			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		9/23/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000		9/2/2010			
5	20	7/1/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
931			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/23/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
6,000		9/2/2010			

Facility Summary in BIG HORN County in the City of LODGE GRASS

Location: OUR LADY OF LORETTO CHURCH
HARDING AVE & HELEN ST
LODGE GRASS, MT 59050 BIG HORN

Sys Fac ID: 02-09970

Last Inspected On: 12/16/2014

Operating Permit Renewal Date: 2/11/2018

Contact: Jim Antoine, (406) 639-2254

Owners/Operators: Our Lady of Loretto Church, Owner (406)-639-2254 PO BOX 509
LODGE GRASS MT 59050-0509
Jim Antoine, UST Class A Operator
Jim Antoine, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	25	7/23/1990	Cathodically Protected Steel	Copper	High Level Alarm
1778			None	PVC	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Heating Oil		12/16/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
3,000		12/16/2014	Gilbarco EMC Basic , Gilbarco		

Facility Summary in BIG HORN County in the City of LODGE GRASS

Location: FARMERS UNION OIL CO LODGE GRASS
 HWY 87 PO BOX 560
 LODGE GRASS, MT 59050 BIG HORN

Sys Fac ID: 02-09976

Last Inspected On: 4/23/2015

Operating Permit Renewal Date: 7/20/2018

Contact: Christel Smith, (406) 639-2413

Owners/Operators: Farmers Union Oil Co Lodge Grass, Owner (406)-639-2505 HC 45 BOX 922
 LODGE GRASS MT 59050-9707

Debra Edwards, UST Class A Operator
 DARIN BIGMEDICINE, UST Class B Operator
 ALVIN EDWARDS, UST Class B Operator
 Debra Edwards, UST Class B Operator
 LORENE FLATMOUTH, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
9	17	12/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3603			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		4/23/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		4/23/2015	TLS-350/Gilbarco EMC , Veeder Root		
10	17	12/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3604			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		4/23/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		4/24/2015	TLS-350/Gilbarco EMC , Veeder Root		
11	17	12/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3605			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		4/23/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		4/23/2015	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in BIG HORN County in the City of LODGE GRASS

Location: LODGE GRASS SCHOOL DIST 27
124 N GEORGE ST
LODGE GRASS, MT 59050 BIG HORN

Sys Fac ID: 02-10772

Last Inspected On: 10/24/2014

Operating Permit Renewal Date: 11/19/2017

Contact: Jim Dabney, (406) 639-2304

Owners/Operators: School Dist 27 Lodge Grass, Owner (406)-639-2304 DRAWER AF
Lodge Grass MT 59050
Leroy Wallace, UST Class A Operator
Leroy Wallace, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	30	4/4/1985	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4361			None	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel		10/17/2011	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor, Deferred	
8,000			TLS-300 , Veeder Root		

Facility Summary in BIG HORN County in the City of PRYOR

Location: PLENTY COUPS HIGH SCHOOL
1 PRYOR SCHOOL LOOP PO BOX 229
PRYOR, MT 59066 BIG HORN

Sys Fac ID: 02-01131

Last Inspected On: 5/15/2015

Operating Permit Renewal Date: 8/26/2018

Contact: (406) 259-7329

Owners/Operators: Plenty Coups High School, Owner (406)-259-7329 PO BOX 229
PRYOR MT 59066-0229
Ross Whiteman, UST Class A Operator
Ross Whiteman, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	17	6/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1824			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		5/15/2015	Automatic Tank Gauging 0.2	Deferred	
1,000			TLS-300 , Veeder Root		
6	17	6/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1825			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		5/15/2015	Automatic Tank Gauging 0.2	Deferred	
2,000			TLS-300 , Veeder Root		

Facility Summary in BIG HORN County in the City of PRYOR

Location: PRYOR SELF SERVICE
704 MAK PUA AVE
PRYOR, MT 59066 BIG HORN

Sys Fac ID: 02-10164

Last Inspected On: 3/3/2014

Operating Permit Renewal Date: 5/16/2017

Contact: William Hoffman, (406) 252-9240

Owners/Operators: William A Hoffman, Owner (406)-252-9240 PO BOX 130
PRYOR MT 59066-0130
William A Hoffman, UST Class A Operator
William A Hoffman, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	17	10/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
1389			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		2/4/2011	Manual Interstitial Monitor	Not Listed	
2,000					

Facility Summary in BIG HORN County in the City of PRYOR

Location: SAINT CHARLES MISSION
 ADDRESS UNKNOWN
 PRYOR, MT 59066 BIG HORN
Contact: Bruce Spotted Bear, (406) 784-2746

Sys Fac ID: 56-04505
Last Inspected On: 12/18/2014
Operating Permit Renewal Date: 2/11/2018

Owners/Operators: St Labre Indian School, Owner (406)-666-2215 1000 TONGUE RIVER RD
 ASHLAND MT 59003
 Dana Davis, UST Class A Operator
 Leney Mcnac, UST Class A Operator
 Ronald Messman, UST Class A Operator
 Dana Davis, UST Class B Global Operator
 Leney Mcnac, UST Class B Global Operator
 Ronald Messman, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	25	8/20/1990	Cathodically Protected Steel	Steel	High Level Alarm
1958			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		12/23/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
1,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in BIG HORN County in the City of SAINT XAVIER

Location: PRETTY EAGLE SCHOOL
PO BOX 257
SAINT XAVIER, MT 59075 BIG HORN

Contact: David Duke, (406) 784-4597

Sys Fac ID: 02-04504
Last Inspected On: 11/5/2013
Operating Permit Renewal Date: 12/31/2016

Owners/Operators: St Labre Indian School, Owner (406)-666-2215 1000 TONGUE RIVER RD
ASHLAND MT 59003

Dana Davis, UST Class A Operator
Leney Mcnac, UST Class A Operator
Ronald Messman, UST Class A Operator
Dana Davis, UST Class B Global Operator
Leney Mcnac, UST Class B Global Operator
Ronald Messman, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	25	4/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1956			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		9/3/2013	Automatic Tank Gauging 0.2	Not Listed	
1,000					
4	25	4/1/1990	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3672			None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Galvanic
Heating Oil		9/3/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor, MLLD Line Tightness Testing	
10,000		11/5/2013			

Facility Summary in BIG HORN County in the City of WYOLA

Location: WYOLA ELEMENTARY SCHOOL
1 MONDELL AVE
WYOLA, MT 59089 BIG HORN

Sys Fac ID: 02-13762

Last Inspected On: 6/29/2013

Operating Permit Renewal Date: 7/12/2016

Contact: Wanda Johnston, (406) 343-2722

Owners/Operators: School Dist 29 Wyola, Owner (406)-343-2722 PO BOX 66
WYOLA MT 59089-0066
Bradford E Crooked Arm Sr, UST Class A Operator
Bradford E Crooked Arm Sr, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	16	7/1/1999	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
4370			Excavation Liner	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		6/29/2013	Automatic Tank Gauging 0.2	Deferred	
1,000					